

**APPROVES THE INSTALLATION OF FIRE HYDRANTS ON WINGS DRIVE
LOCATED WITHIN THE CITY OF CHESTERFIELD**

WHEREAS, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

WHEREAS, it is necessary for the authorization of the placement of said fire hydrants by ordinance.

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:

Section 1. The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

- a. Nine (9) fire hydrants in Wings Corporate Estates Subdivision as follows:
 1. One on the north side of Wings Dr. at the east boundary of subdivision.
 2. One on the north side of Wings Dr. 300 ft. west of the east boundary of subdivision.
 3. One on the north side of Wings Dr. 600 ft. west of the east boundary of subdivision.
 4. One on the north side of Wings Dr. 900 ft. west of the east boundary of subdivision.
 5. One on the north side of Wings Dr. 1200 ft. west of the east boundary of subdivision.
 6. One on the north side of Wings Dr. 1500 ft. west of the east boundary of subdivision.
 7. One on the north side of Wings Dr. 1800 ft. west of the east boundary of subdivision.
 8. One on the north side of Wings Dr. 2100 ft. west of the east boundary of subdivision.
 9. One on the north side of Wings Dr. 2400 ft. west of the east boundary of subdivision.


Section 2. The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid locations.

Section 3. This ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this 13th day of JUNE, 2005.


Mayor

ATTEST:


City Clerk


ACTING MAYOR

6/6/05
DATE

I, Clifford Biele, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 26th day of May, 2005, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 9 fire hydrant(s) on Wings Drive as follows:

1. One on the north side of Wings Dr, at east boundary of subdivision.
2. One on the north side of Wings Dr, 300' west of the east boundary of subdivision.
3. One on the north side of Wings Dr, 600' west of the east boundary of subdivision.
4. One on the north side of Wings Dr, 900' west of the east boundary of subdivision.
5. One on the north side of Wings Dr, 1200' west of the east boundary of subdivision.
6. One on the north side of Wings Dr, 1500' west of the east boundary of subdivision.
7. One on the north side of Wings Dr, 1800' west of the east boundary of subdivision.
8. One on the north side of Wings Dr, 2100' west of the east boundary of subdivision.
9. One on the north side of Wings Dr, 2400' west of the east boundary of subdivision.

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for Wings Drive to be 3000 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 26th day of May, 2005.


FIRE CHIEF