

APPROVES THE INSTALLATION OF FIRE HYDRANTS IN WINGS CORPORATE ESTATES LOCATED WITHIN THE CITY OF CHESTERFIELD

WHEREAS, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

WHEREAS, it is necessary for the authorization of the placement of said fire hydrants by ordinance.

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:

Section 1. The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

- a. Five (5) fire hydrants on Wings Drive and Buzz Westfall Drive, as follows:
 - 1. One on the east side of Buzz Westfall Dr. 280' south of the centerline of Wings Dr.
 - 2. One on the east side of Buzz Westfall Dr. 580' south of the centerline of Wings Dr.
 - 3. One on the north side of Paul Haglin Dr. 350' east of the centerline of Buzz Westfall Dr.
 - 4. One on the north side of Paul Haglin Dr. 850' east of the centerline of Buzz Westfall Dr.
 - 5. One on the north side of Paul Haglin Dr. 1150' east of the centerline of Buzz Westfall Dr.


Section 2. The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid locations.

Section 3. This ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this 18th day of July, 2005.


Mayor

ATTEST:


City Clerk

I, Clifford Biele, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 20th day of June, 2005, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 5 fire hydrant(s) in Wings Corporate Estates, as follows:


1. One on the east side of Buzz Westfall Dr, 280' south of the centerline of Wings Dr.
2. One on the east side of Buzz Westfall Dr, 580' south of the centerline of Wings Dr.
3. One on the north side of Paul Haglin Dr, 350 east of the centerline of Buzz Westfall Dr.
4. One on the north side of Paul Haglin Dr, 850 east of the centerline of Buzz Westfall Dr.
5. One on the north side of Paul Haglin Dr, 1150 east of the centerline of Buzz Westfall Dr.

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for Wings Corporate Estates to be 3000 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 20th day of June, 2005.



FIRE CHIEF