

BILL NO. 2697

ORDINANCE NO. 2517

**APPROVES THE INSTALLATION OF SEVEN FIRE HYDRANTS IN
THE SPIRIT OF ST. LOUIS CORPORATE CENTER
LOCATED WITHIN THE CITY OF CHESTERFIELD**

WHEREAS, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

WHEREAS, it is necessary for the authorization of the placement of said fire hydrants by ordinance.

NOW, THEREFORE, BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:

Section 1. The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

a. Six (6) fire hydrants on Spirit Commerce Drive:

1. West side of Spirit Commerce Drive, 429 feet north of the centerline of Chesterfield Airport Road.
2. West side of Spirit Commerce Drive, 151 feet north of the centerline of Chesterfield Airport Road.
3. South side of Spirit Commerce Drive, 232 feet east of the centerline of Spirit of St. Louis Boulevard.
4. South side of Spirit Commerce Drive, 498 feet east of the centerline of Spirit of St. Louis Boulevard.
5. South side of Spirit Commerce Drive, 798 feet east of the centerline of Spirit of St. Louis Boulevard.
6. South side of Spirit Commerce Drive, 1067 feet east of the centerline of Spirit of St. Louis Boulevard.


b. One (1) fire hydrant on Spirit of St. Louis Boulevard:

1. East side of Spirit of St. Louis Boulevard, 50 feet south of the centerline of Spirit Commerce Drive.

Section 2. The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid locations.

Section 3. This ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this 22nd day of April, 2009.



Mayor

ATTEST:



City Clerk

[FIRST READING HELD: _____]

I, Clifford Biele, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 23rd day of March, 2009, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 7 fire hydrant(s) in Spirit of St Louis Corporate Center, as follows:

1. One on the west side of Spirit Commerce Dr, 429' north of the center line of Chesterfield Airport Rd
2. One on the west side of Spirit Commerce Dr, 151' north of the center line of Chesterfield Airport Rd
3. One on the south side of Spirit Commerce Dr, 232' east of the center line of Spirit of St. Louis Blvd.
4. One on the south side of Spirit Commerce Dr, 498' east of the center line of Spirit of St. Louis Blvd.
5. One on the south side of Spirit Commerce Dr, 798' east of the center line of Spirit of St. Louis Blvd.
6. One on the south side of Spirit Commerce Dr, 1067' east of the center line of Spirit of St. Louis Blvd.
7. One on the east side of Spirit of St. Louis Blvd, 50' south of the center line of Spirit Commerce Dr.

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for Spirit of St Louis Corporate Center to be 1500 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 23rd day of March, 2009.



FIRE CHIEF