

BILL NO. 2885

ORDINANCE NO. 2702

APPROVES THE INSTALLATION OF THREE FIRE HYDRANTS AT THE ARBORS AT WILDHORSE CREEK LOCATED WITHIN THE CITY OF CHESTERFIELD.

WHEREAS, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

WHEREAS, it is necessary for the authorization of the placement of said fire hydrants by ordinance.

NOW THEREFORE BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:

Section 1. The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

a. Three (3) fire hydrants at the following locations:

1. One on the east side of Arbor Grove Court at the north side of lot 22.
2. One on the east side of Arbor Grove Court at a point 1,200 feet south of the centerline of Wildhorse Creek Road.
3. One on the east side of Arbor Grove Court at a point 1,800 feet south of the centerline of Wildhorse Creek Road.

Section 2. The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid location.

Section 3. This Ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this 21st day of May, 2012.

J. Bruce Heiger
MAYOR

ATTEST:

Vickie Haas
~~CITY CLERK~~
Deputy City Clerk

FIRST READING HELD: _____

I, Thomas J. Vineyard, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 16th day of April, 2012, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 3 public fire hydrant(s) in Arbors at Wildhorse Creek (subdivision) as follows:


1. On the east side of Arbor Grove Court at the north side of lot 22.
2. On the east side of Arbor Grove Court at a point 1,200 feet south of the centerline of Wildhorse Creek Road.
3. On the east side of Arbor Grove Court at a point 1,800 feet south of the centerline of Wildhorse Creek Road.

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for Arbors at Wildhorse Creek (subdivision) to be 2,250 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said 3 public fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 16th day of April, 2012.


FIRE CHIEF