

BILL NO. 3114

ORDINANCE NO. 2913

**APPROVES THE INSTALLATION OF NINE FIRE HYDRANTS IN THE ARBORS AT WILMAS FARM SUBDIVISION WITHIN THE CITY OF CHESTERFIELD.**

**WHEREAS**, at a duly called meeting of the Board of Directors of the Monarch Fire Protection District, the placement of certain fire hydrants was approved; and,

**WHEREAS**, it is necessary for the authorization of the placement of said fire hydrants by ordinance.

**NOW THEREFORE BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF CHESTERFIELD, ST. LOUIS COUNTY, MISSOURI, AS FOLLOWS:**

**Section 1.** The placement of the following fire hydrants at such exact locations as specified by the Insurance Services Office of Missouri and as approved by the Board of Directors of the Monarch Fire Protection District is hereby approved by the City of Chesterfield for installation:

a. Nine (9) fire hydrants at the following locations:

1. One on the west side of Wilmas Farm Drive at a point approximately 400 feet south of the centerline of Wild Horse Creek Road.
2. One on the northwest corner of the intersection of Wilmas Farm Drive and Wilmas Hollow Drive.
3. One on the west side of Wilmas Farm Drive at the intersection of lots 42 and 43.
4. One on the west side of Wilmas Farm Drive at a point approximately 120 feet north of the centerline of Wilmas Valley Court.
5. One on the west side of Wilmas Farm Drive at a point approximately 110 feet south of the centerline of Wilmas Valley Court.
6. One on the south side of Wilmas Hollow Drive at a point approximately 60 feet west of the centerline of Deep Forest Drive.
7. One on the south side of Wilmas Hollow Drive at the intersection of lots 14 and 15.
8. One on the east side of Wilmas Valley Court at a point approximately 400 feet from the centerline of Wilmas Farm Drive.
9. One on the east side of Wilmas Valley Court at the intersection of lots 31 and 32.

**Section 2.** The Missouri American Water Company is authorized to install said fire hydrants at the aforesaid locations.

**Section 3.** This Ordinance shall be in full force and effect from and after its passage and approval.

Passed and approved this 5<sup>TH</sup> day of October, 2016.

Bob Nation  
PRESIDING OFFICER

Bob Nation  
Bob Nation, MAYOR

ATTEST:

Vickie Hass  
Vickie Hass, CITY CLERK

FIRST READING HELD: 10/5/2016

I, Cary Spiegel, Fire Chief of the Monarch Fire Protection District, Incorporated as a political subdivision under the laws of the STATE OF MISSOURI, DO HERE BY CERTIFY that at a meeting of the Board of Directors of said Fire District, duly called and held on the 25<sup>th</sup> day of August, 2016, at which a quorum was present, the following action was taken:

"Upon motion duly made, seconded and carried, the following resolution was unanimously adopted."

WHEREAS, pursuant to MISSOURI PUBLIC SERVICE COMMISSION ORDER NO. 4, issued on November the 28th, 1969, Missouri-American Water Company has promulgated certain rules relating to the location of fire hydrants by incorporated Fire Districts: and,

WHEREAS, The Insurance Services Office of Missouri has specified the location of 9 public fire hydrant(s) in **The Arbors at Wilmas Farm** (subdivision) as follows:

1. On the west side of Wilmas Farm Drive at a point approximately 400 feet south of the centerline of Wild Horse Creek Road.
2. On the northwest corner of the intersection of Wilmas Farm Drive and Wilmas Hollow Drive.
3. On the west side of Wilmas Farm Drive at the intersection of lots 42 and 43.
4. On the west side of Wilmas Farm Drive at a point approximately 120 feet north of the centerline of Wilmas Valley Court.
5. On the west side of Wilmas Farm Drive at a point approximately 110 feet south of the centerline of Wilmas Valley Court.
6. On the south side of Wilmas Hollow Drive at a point approximately 60 feet west of the centerline of Deep Forest Drive.
7. On the south side of Wilmas Hollow Drive at the intersection of lots 14 and 15.
8. On the east side of Wilmas Valley Court at a point approximately 400 feet from the centerline of Wilmas Farm Drive.
9. On the east side of Wilmas Valley Court at the intersection of lots 31 and 32.

WHEREAS, The Insurance Services Office of Missouri has specified the minimum fire flow for **The Arbors at Wilmas Farm** (subdivision) to be 2,250 GPM at 20 PSIG:

WHEREAS, for the purpose of keeping fire insurance rated as low as possible, the MONARCH FIRE PROTECTION DISTRICT has always fixed the location of fire hydrants, and fire flows in accordance with the recommendations of the Insurance Service Office of Missouri:

NOW THEREFORE, BE IT RESOLVED, that the Missouri-American Water Company install said 9 public fire hydrant(s) at the aforesaid location(s),

IN WITNESS THEREOF, I have hereunto set my hand as Fire Chief of the Monarch Fire Protection District, and have caused the corporate seal of said Fire District to be affixed this 25<sup>th</sup> day of August, 2015.

---

FIRE CHIEF